

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Proline Floors
PO Box 2438
Taren Point NSW 2229

Test Number : 17-003295
Issue Date : 11/07/2017
Print Date : 20/07/2017

Sample Description Clients Ref : "Plantino Laminate Deluxe Classic"
Engineered Flooring
End Use : Floating Floors
Nominal Composition : Melamine Outer MDF Core
Nominal Mass per Unit Area/Density : 11kg/m²
Nominal Thickness : 12mm

AS 4586-2013
Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Test 07/07/2017
Test Temperature (20±5degC) 22 °C
Sample Preparation Sample washed with PH detergent and dried.
Test Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 67
Length 1 2 3 4 5 SRV
British Pendulum Number 41 40 39 39 38 39
Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 02/09/2015
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

98497

20402

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR