AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

Abode Prime - FIRE TEST REPORT

Client: Proline Floors

Sample Description

Unit 2

33 - 35 Captain Cook Drive Caringbah NSW 2229

> "Abode Prime" PVC Floor Panels Clients Ref:

End Use: Floating Flooring

Nominal Composition: PVC/Calcium Carbonate 9800g/m2 Nominal Mass per Unit Area/Density:

Nominal Thickness: 6mm

AS/ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Radiant Heat Source

Date of Sample Arrival 06/11/2017 **Date Tested** 24/11/2017

CHF Value 1 2 3 Mean Length 7.3 7.1 7.3 kW/m² Width 7.7 kW/m² Smoke Value 2 3 1 Mean Length 92 152 158 134 %.min Width 176 %.min

Melting Yes Blistering Yes

112290 23652 Page 1 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Chemical Testing

Mechanical Testing

Performance & Approvals Testing

: Accreditation No

Accreditation No

· Accreditation No. 1356

983

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



A. JACKSON B.Sc.(Hons)

17-006258

24/11/2017

24/11/2017

Abode Test

Test Number :

Order Number:

Issue Date

Print Date

AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

Abode Prime - FIRE TEST REPORT

Client: Proline Floors

Unit 2

33 - 35 Captain Cook Drive Caringbah NSW 2229

Test Number :

17-006258

Issue Date

24/11/2017

Print Date Order Number:

24/11/2017 Abode Test

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

112290 23652 Page 2 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



the Managing Director of AWTA Ltd.

Accredited for compliance with ISO/IEC 17025 - Chemical Testing Mechanical Testing

Performance & Approvals Testing

: Accreditation No

Accreditation No · Accreditation No.

983 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by



A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY